

College Achieve Central Charter School

107 Westervelt Ave.
North Plainfield, NJ 07062

Analytical Results for Lead

JR Henderson Labs, Inc.
123 Seaman Ave.
Beachwood, NJ 08722
732-341-1211
Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

College Achieve Central Charter School
107 Westervelt Ave
North Plainfield, NJ 07062

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
25-3024.1	Field Blank	6-4-25	06:30	LEAD	200.8	<0.30	6-10-25	10:05	15
25-3024.2	Water Fountain-Cafeteria	6-4-25	06:30	LEAD	200.8	<0.30	6-10-25	10:14	15
25-3024.3	Art Room Sink	6-4-25	06:32	LEAD	200.8	<0.30	6-10-25	10:17	15
25-3024.4	Training Room Sink	6-4-25	06:33	LEAD	200.8	<0.30	6-10-25	10:20	15
25-3024.5	Room 107 Science Lab	6-4-25	06:35	LEAD	200.8	<0.30	6-10-25	10:23	15
25-3024.6	Water Fountain-1st Floor	6-4-25	06:37	LEAD	200.8	<0.30	6-10-25	10:26	15
25-3024.7	Nurse Office Sink	6-4-25	06:38	LEAD	200.8	<0.30	6-10-25	10:29	15
25-3024.8	Room 121 Lab Sink	6-4-25	06:40	LEAD	200.8	<0.30	6-10-25	10:38	15
25-3024.9	Teachers' Lounge	6-4-25	06:43	LEAD	200.8	<0.30	6-10-25	10:41	15
25-3024.10	Water Fountain-2nd Floor	6-4-25	06:44	LEAD	200.8	<0.30	6-10-25	10:44	15
25-3024.11	Water Fountain-3rd Floor	6-4-25	06:46	LEAD	200.8	<0.30	6-10-25	10:47	15
25-3024.12	Mrs. Brown's Office	6-4-25	06:48	LEAD	200.8	<0.30	6-10-25	10:50	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 6-11-25

College Achieve Central Charter School
107 Westervelt Ave.

Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	25-3024.1	JRH Labs	15083	6/4/2025	06:30	200.8	6/10/2025	10:05	<0.30	0.30	1	N	
Water Fountain-Cafeteria	N	25-3024.2	JRH Labs	15083	6/4/2025	06:30	200.8	6/10/2025	10:14	<0.30	0.30	1	N	
Art Room Sink	N	25-3024.3	JRH Labs	15083	6/4/2025	06:32	200.8	6/10/2025	10:17	<0.30	0.30	1	N	
Training Room Sink	N	25-3024.4	JRH Labs	15083	6/4/2025	06:33	200.8	6/10/2025	10:20	<0.30	0.30	1	N	
Room 107 Science Lab	N	25-3024.5	JRH Labs	15083	6/4/2025	06:35	200.8	6/10/2025	10:23	<0.30	0.30	1	N	
Water Fountain-1st Floor	N	25-3024.6	JRH Labs	15083	6/4/2025	06:37	200.8	6/10/2025	10:26	<0.30	0.30	1	N	
Nurse Office Sink	N	25-3024.7	JRH Labs	15083	6/4/2025	06:38	200.8	6/10/2025	10:29	<0.30	0.30	1	N	
Room 121 Lab Sink	N	25-3024.8	JRH Labs	15083	6/4/2025	06:40	200.8	6/10/2025	10:38	<0.30	0.30	1	N	
Teachers Lounge	N	25-3024.9	JRH Labs	15083	6/4/2025	06:43	200.8	6/10/2025	10:41	<0.30	0.30	1	N	
Water Fountain-2nd Floor	N	25-3024.10	JRH Labs	15083	6/4/2025	06:44	200.8	6/10/2025	10:44	<0.30	0.30	1	N	
Water Fountain-3rd Floor	N	25-3024.11	JRH Labs	15083	6/4/2025	06:46	200.8	6/10/2025	10:47	<0.30	0.30	1	N	
Mrs. Brown's Office	N	25-3024.12	JRH Labs	15083	6/4/2025	06:48	200.8	6/10/2025	10:50	<0.30	0.30	1	N	

Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

CLIENT INFORMATION

Name: College Achieve Charter School
Address: 365 Emerson Ave., Plainfield, NJ 07062
Client Rep: Abraham Solorzano 908-625-1879

LAB INFORMATION

Name: JR Henderson Labs, Inc.
Address: 123 Seaman Ave., Beachwood, NJ 08722
Lab Mgr.: Trevor Ellis

SCHOOL/PROJECT INFORMATION

Bldg : College Achieve Charter School
Bldg No:
Bldg Address: 107 Westervelt Ave., North Plainfield, NJ 07060
Contact Name & Number: Abraham Solorzano 908-625-1879

SAMPLE DATA – ID & Location must match container label

LAB USE	Sample ID	LEAVE BLANK	Sampled Outlet Location	Date	Time (24hr)	First Draw	Flushed
	25-3024.1		Field Blank	6/4/25	6:30 AM	X	
	25-3024.2		Water fountain Cafeteria	6/4/25	6:30 AM	X	
	25-3024.3		Art Room	6/4/25	6:32 AM	X	
	25-3024.4		Training Room	6/4/25	6:33 AM	X	
	25-3024.5		107 Science lab	6/4/25	6:35 AM	X	
	25-3024.6		Water fountain 1st Fl	6/4/25	6:37 AM	X	
	25-3024.7		Nurses office	6/4/25	6:38 AM	X	
	25-3024.8		121 Science lab	6/4/25	6:40 AM	X	
	25-3024.9		Teacher's lounge	6/4/25	6:43 AM	X	
	25-3024.10		Water fountain 2nd Fl	6/4/25	6:44 AM	X	
	25-3024.11		water fountain 3rd Fl	6/4/25	6:46 AM	X	
	25-3024.12		Mrs. Brown's office	6/4/25	6:48 AM	X	
						X	

All containers are pre-cleaned/ 250 ml plastic bottles preserved w/ HNO₃ @ pH<2 to be preserved by lab

CHAIN OF CUSTODY

Relinquished By:	Date/Time:	Received By:	Date/Time:
Abraham Solorzano	6/5/25 2:49 PM	[Signature]	6/9/25 11:15

Method of shipment/delivery: ☒ Fed-Ex ☐ Hand Delivery ☐ Other:___

INSTRUCTIONS TO THE LABORATORY

Analyze both initial and follow up samples ___ Other: ☒ Follow QAPP instructions	Lab: JR Henderson Labs 123 Seaman Ave. Beachwood, NJ 08722 Contact: Stacey Yuro syuro@henderson-labs.com	Report Results to: ___ Phone ☒ Email: asolorzano@collegeachieve.org
--	--	--

Comments: Provide Laboratory Data Report (LDR) Package and Chain of Custody