

College Achieve Central Charter School

1225 South Ave.
Plainfield, NJ 07062

Analytical Results for Lead

JR Henderson Labs, Inc.
123 Seaman Ave.
Beachwood, NJ 08722
732-341-1211
Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

College Achieve Central Charter School
1225 South Ave.
Plainfield, NJ 07062

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
25-3025.1	Field Blank	6-5-25	06:34	LEAD	200.8	<0.30	6-10-25	09:04	15
25-3025.2	Teachers' Lounge	6-5-25	06:35	LEAD	200.8	<0.30	6-10-25	09:13	15
25-3025.3	Room 205	6-5-25	06:37	LEAD	200.8	<0.30	6-10-25	09:16	15
25-3025.4	2nd Floor-6th Grade Hall-Water Fountain	6-5-25	06:38	LEAD	200.8	<0.30	6-10-25	09:19	15
25-3025.5	1st Floor-8th Grade Water Fountain by Bathroom	6-5-25	06:40	LEAD	200.8	<0.30	6-10-25	9:22	15
25-3025.6	Kitchen	6-5-25	06:47	LEAD	200.8	<0.30	6-10-25	09:31	15
25-3025.7	Nurse's Office	6-5-25	06:50	LEAD	200.8	<0.30	6-10-25	09:34	15
25-3025.8	1st Floor-8th Grade Water Fountain 2 by Room 120	6-5-25	06:55	LEAD	200.8	<0.30	6-10-25	09:37	15
25-3025.9	7th Grade Hall-Water Fountain	6-5-25	06:55	LEAD	200.8	<0.30	6-10-25	09:40	15
25-3025.10	2nd Floor-Water Fountain by Teachers' Lounge	6-5-25	07:00	LEAD	200.8	<0.30	6-10-25	09:43	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 6-11-25

College Achieve Central Charter School
1225 South Ave
Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank Teachers' Lounge Room 205	N	25-3025.1	JRH Labs	15083	6/5/2025	06:34	200.8	6/10/2025	09:04	<0.30	0.30	1	N	
	N	25-3025.2	JRH Labs	15083	6/5/2025	06:35	200.8	6/10/2025	09:13	<0.30	0.30	1	N	
	N	25-3025.3	JRH Labs	15083	6/5/2025	06:37	200.8	6/10/2025	09:16	<0.30	0.30	1	N	
2nd Floor-6th Grade Hall-Water Fountain	N	25-3025.4	JRH Labs	15083	6/5/2025	06:38	200.8	6/10/2025	09:19	<0.30	0.30	1	N	
1st Floor-8th Grade Water Fountain by Bathroom	N	25-3025.5	JRH Labs	15083	6/5/2025	06:40	200.8	6/10/2025	9:22	<0.30	0.30	1	N	
Kitchen	N	25-3025.6	JRH Labs	15083	6/5/2025	06:47	200.8	6/10/2025	09:31	<0.30	0.30	1	N	
Nurse's Office	N	25-3025.7	JRH Labs	15083	6/5/2025	06:50	200.8	6/10/2025	09:34	<0.30	0.30	1	N	
1st Floor-8th Grade Water Fountain 2 by Room 120	N	25-3025.8	JRH Labs	15083	6/5/2025	06:55	200.8	6/10/2025	09:37	<0.30	0.30	1	N	
7th Grade Hall-Water Fountain	N	25-3025.9	JRH Labs	15083	6/5/2025	06:55	200.8	6/10/2025	09:40	<0.30	0.30	1	N	
2nd Floor-Water Fountain by Teachers' Lounge	N	25-3025.10	JRH Labs	15083	6/5/2025	07:00	200.8	6/10/2025	09:43	<0.30	0.30	1	N	

Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

CLIENT INFORMATION

Name: College Achieve Charter School
Address: 365 Emerson Ave., Plainfield, NJ 07062
Client Rep: Abraham Solorzano 908-625-1879

LAB INFORMATION

Name: JR Henderson Labs, Inc.
Address: 123 Seaman Ave., Beachwood, NJ 08722
Lab Mgr.: Trevor Ellis

SCHOOL/PROJECT INFORMATION

Bldg : College Achieve Charter School
Bldg No:
Bldg Address: 1225 South Ave., Plainfield, NJ 07062
Contact Name & Number: Abraham Solorzano 908-625-1879

SAMPLE DATA – ID & Location must match container label

LAB USE	Sample ID	Sample Location	Date	Time (24hr)	First Draw	Flushed
	25-3025.1	Field Blank	6/5/25	6:34 AM	X	
	25-3025.2	Teacher's lounge	6/5/25	6:35 AM	X	
	25-3025.3	Room 205	6/5/25	6:37 AM	X	
	25-3025.4	2nd Fl 6th grade hallway water fountain	6/5/25	6:38 AM	X	
	25-3025.5	1st Fl by bathroom 8th grade water fountain 1	6/5/25	6:40 AM	X	
	25-3025.6	Kitchen	6/5/25	6:47 AM	X	
	25-3025.7	Nurse's office	6/5/25	6:50 AM	X	
	25-3025.8	1st Fl by room 120 8th grade water fountain 2	6/5/25	6:55 AM	X	
	25-3025.9	7th grade hallway - water fountain	6/5/25	6:55 AM	X	
	25-3025.10	2nd Fl by teacher's lounge water fountain	6/5/25	7:00 AM	X	

All containers are pre-cleaned/ 250 ml plastic bottles preserved w/ HNO₃ @ pH<2 to be preserved by lab

CHAIN OF CUSTODY

Relinquished By:	Date/Time:	Received By:	Date/Time:
Abraham Solorzano	6/5/25 2:45 PM	<i>[Signature]</i>	6/9/25 11:15

Method of shipment/delivery: ☒ Fed-Ex ☐ Hand Delivery ☐ Other:___

INSTRUCTIONS TO THE LABORATORY

Analyze both initial and follow up samples Other: ☒ Follow QAPP instructions	Lab: JR Henderson Labs 123 Seaman Ave. Beachwood, NJ 08722 Contact: Stacey Yuro syuro@henderson-labs.com	Report Results to: Phone ☒ Email: asolorzano@collegeachieve.org
---	--	---

Comments: Provide Laboratory Data Report (LDR) Package and Chain of Custody