

College Achieve Central Charter School

365 Emerson Ave.
Plainfield, NJ 07062

Analytical Results for Lead

JR Henderson Labs, Inc.
123 Seaman Ave.
Beachwood, NJ 08722
732-341-1211
Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

College Achieve Central Charter School
365 Emerson Ave.
Plainfield, NJ 07062

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
25-3026.1	Field Blank	6-5-25	06:36	LEAD	200.8	<0.30	6-10-25	11:34	15
25-3026.2	Conference Room	6-5-25	06:03	LEAD	200.8	2.42	6-10-25	11:43	15
25-3026.3	Nurse's Office	6-5-25	06:09	LEAD	200.8	1.87	6-10-25	11:46	15
25-3026.4	Kitchen	6-5-25	05:52	LEAD	200.8	4.25	6-10-25	11:49	15
25-3026.5	1 st Floor Water Fountain	6-5-25	06:15	LEAD	200.8	<0.30	6-10-25	11:52	15
25-3026.6	Room 108	6-5-25	06:11	LEAD	200.8	4.62	6-10-25	11:55	15
25-3026.7	Gym Water Fountain	6-5-25	06:05	LEAD	200.8	<0.30	6-10-25	11:58	15
25-3026.8	2 nd Floor Water Fountain	6-5-25	06:21	LEAD	200.8	<0.30	6-10-25	12:07	15
25-3026.9	Teacher's Lounge	6-5-25	06:18	LEAD	200.8	2.27	6-10-25	12:10	15
25-3026.10	3 rd Floor Water Fountain	6-5-25	06:26	LEAD	200.8	<0.30	6-10-25	12:13	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 6-11-25

College Achieve Central Charter School
365 Emerson Ave., Plainfield

Lead Results

Field ID	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	25-3026.1	JRH Labs	15083	6/5/2025	06:36	200.8	6/10/2025	11:34	<0.30	0.30	1	N	
Conference Room	N	25-3026.2	JRH Labs	15083	6/5/2025	06:03	200.8	6/10/2025	11:43	2.42	0.30	1	N	
Nurse's Office	N	25-3026.3	JRH Labs	15083	6/5/2025	06:09	200.8	6/10/2025	11:46	1.87	0.30	1	N	
Kitchen	N	25-3026.4	JRH Labs	15083	6/5/2025	05:52	200.8	6/10/2025	11:49	4.25	0.30	1	N	
1st Floor Water Fountain	N	25-3026.5	JRH Labs	15083	6/5/2025	06:15	200.8	6/10/2025	11:52	<0.30	0.30	1	N	
Room 108	N	25-3026.6	JRH Labs	15083	6/5/2025	06:11	200.8	6/10/2025	11:55	4.62	0.30	1	N	
Gym Water Fountain	N	25-3026.7	JRH Labs	15083	6/5/2025	06:05	200.8	6/10/2025	11:58	<0.30	0.30	1	N	
2nd Floor Water Fountain	N	25-3026.8	JRH Labs	15083	6/5/2025	06:21	200.8	6/10/2025	12:07	<0.30	0.30	1	N	
Teachers' Lounge	N	25-3026.9	JRH Labs	15083	6/5/2025	06:18	200.8	6/10/2025	12:10	2.27	0.30	1	N	
3rd Floor Water Fountain	N	25-3026.10	JRH Labs	15083	6/5/2025	06:26	200.8	6/10/2025	12:13	<0.30	0.30	1	N	

Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

CLIENT INFORMATION

Name: College Achieve Charter School
Address: 365 Emerson Ave., Plainfield, NJ 07062
Client Rep: Abraham Solorzano 908-625-1879

LAB INFORMATION

Name: JR Henderson Labs, Inc.
Address: 123 Seaman Ave., Beachwood, NJ 08722
Lab Mgr.: Trevor Ellis

SCHOOL/PROJECT INFORMATION

Bldg : College Achieve Charter School
Bldg No:
Bldg Address: 365 Emerson Ave., Plainfield, NJ 07062
Contact Name & Number: Abraham Solorzano 908-625-1879

SAMPLE DATA – ID & Location must match container label

LAB USE	Sample ID	Sampled Outlet Location	Date	Time (24hr)	First Draw	Flushed
	25-3026.1	Field Blank	6/5/25	6:36 AM	X	
	25-3026.2	Conference room	6/5/25	6:38 AM	X	
	25-3026.3	Nurse's office	6/5/25	6:09 AM	X	
	25-3026.4	Kitchen	6/5/25	5:52 AM	X	
	25-3026.5	1st fl water fountain	6/5/25	6:15 AM	X	
	25-3026.6	Room 108	6/5/25	6:11 AM	X	
	25-3026.7	Gym water fountain	6/5/25	6:05 AM	X	
	25-3026.8	2nd fl water fountain	6/5/25	6:21 AM	X	
	25-3026.9	Teacher's lounge	6/5/25	6:18 AM	X	
	25-3026.10	3rd fl water fountain	6/5/25	6:26 AM	X	

All containers are pre-cleaned/ 250 ml plastic bottles preserved w/ HNO₃ @ pH<2 to be preserved by lab

CHAIN OF CUSTODY

Relinquished By: Abraham Solorzano	Date/Time: 6/5/25 2:54 PM	Received By: 	Date/Time: 6/9/25 11:15

Method of shipment/delivery: ☒ Fed-Ex ☐ Hand Delivery ☐ Other:___

INSTRUCTIONS TO THE LABORATORY

Analyze both initial and follow up samples Other:___ ☒ Follow QAPP instructions	Lab: JR Henderson Labs 123 Seaman Ave. Beachwood, NJ 08722 Contact: Stacey Yuro syuro@henderson-labs.com	Report Results to: Phone ☒ Email: asolorzano@collegeachieve.org
---	--	---

Comments: Provide Laboratory Data Report (LDR) Package and Chain of Custody